

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3725-0610:130

Page 1 of 1

**CATEGORY:** Door Hardware (Fire-Rated)

**LISTEE:** Dorma Door Controls, Drawer AC, Reamstown, PA 17567  
Contact: Rick Loose (717) 336-3881

**DESIGN:** Models F5100 (concealed vertical rod), F5300 (single point rim type latch), F5400 surfaced mounted vertical rod) and F5500 (single point mortised lock) fire exit hardware. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, NFPA 80, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed fire exit hardware for use with swinging type fire doors (3 Hrs) measuring up to 4' in width by 10' in high (single) and 8' in width by 10' in high (double) where permitted per code.

05-27-2002 BH



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 3, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager